

HIGH COURT OF CHHATTISGARH, BILASPUR

Tender Notice

No. 15560 /CPC/2022

Bilaspur, dated 20 /12/2022

Sealed estimates/quotations are invited from the intending firms having valid GST and PAN Numbers for Supply, Testing, Installation & Maintenance of following articles:-

Sl. No.	Name of the Articles	Quantity
1.	UPS (1100VA/230V capacity) with minimum 30 minutes backup	05


Terms and Conditions:-

- The Firm will submit its written undertaking for providing warranty of the aforementioned articles, during the warranty period as provided by the OEM for further three years including battery.
- The Firm will submit EMD charge of 3 percent of the quoted amount in round figures in the name of Registrar General, High Court of Chhattisgarh, Bilaspur at the time of submission of quotations, same will be returned to the firm as per the Chhattisgarh Store Purchase Rules 2002.
- The Firm should be established Office/Service Center/Field Engineer at Bilaspur/Raipur of the Chhattisgarh State (Kindly attach the details with quotations like address, Name of the Offices/Proprietor with e-mail ID and Mobile Numbers).
- The Firm shall submit the rates of only good quality heavy duty use Products, which are available with the bidders and on being demanded, firm will supply the said articles within a week.
- All the devices that is supplied should be genuine and legal.
- Required quantity of aforementioned articles may be increased or decreased. It will depend on our actual requirement.
- The minimum required specification of UPS is attached herewith as annexure-"A".
- Bidder will submit standard certification of the articles like BIS, Safety, Energy, etc.
- Bidder must have to provide same day support during warranty period.
- Unit Price of article should be including packing, forwarding, freight, insurance, installation, configuration, commissioning, warranty, comprehensive maintenance for three years warranty period or any other charges, in following format:-

➤ Details of Price of following articles:-

Sl. No.	Name of the article	Unit Price of Item (In Rs.)	Required Quantity of articles	Total price of item (In Rs.)	GST (In Rs.)	Total (In Rs.)
(A)	(B)	(C)	(D)	(E=C*D)	F	(G=E+F)
1.	UPS (1100VA/230V capacity) with minimum 30 minutes backup		05			

Estimate/Quotations must be submitted to the Registrar General, High Court of Chhattisgarh, Bilaspur either personally or through authorized agents or by Post on or before 04:30 PM of 02/01/2023, which will be opened on next working day i.e. on 03/01/2023, after 12:00 AM. Estimates/quotations received through e-mail or after the specified date will not be taken into consideration and the Registrar General of this High Court reserve every right to rejecting any estimates/quotations without assigning any reason thereof.


Arvind Kumar Verma
Registrar General
20.12.2022

MINIMUM SPECIFICATION OF UPS FOR COMPUTERS

Capacity	1100 VA line Interactive
Input Voltage and Frequency	145-270V, 47 to 53 Hz
Output Voltage and Frequency (On Mains)	220 +/- 8% with AVR (Automatic Voltage Regulation), 50Hz (47-63 Hz) synchronized with Input Power Frequency
Output Voltage and Frequency (On Battery)	230 V +/- 3% with 50 Hz
Backup Time	30 Minutes
Battery Type	Maintenance-free and leak proof
Efficiency	70% or more
Output Wave-type	Quasi Sine Wave or better
Transfer Time	<=10 milliseconds
Load Power Factor	0.6 leading to unity
Other Features	Cold Start, Auto Start, Generator Compatible
Protections from	Surge, Short Circuit, Spikes, DC Under-voltage and overload, Low Battery
Indicators	Mains On, Battery, Charge, Overload
Alarms	Low Battery, Mains Off, Tripping
Operating Environment	0-40°C
Operating Relative Humidity	0-90%
Audible noise at 1 meter from surface of unit	Not more than 50.00 db A
Output Sockets	3 or more with 3 pin

